



74 Kent Street
Brooklyn, New York 11222-1517

Phone (718) 383-5080
Fax (718) 383-7445
E-mail: dllabs@aol.com

Independent Testing and Consulting Laboratory Serving the Coatings, Sealant,
Waterproofing and Building Materials Industries Since 1932

October 5, 2010

Tagawa Sangyo Company, Ltd.
1924 Yugeta, Tagawa-shi, Fukuoka-ken,
826-0041 Japan

Attn: **Mr. Nobuyoshi Yukihiro**

Re: DL-16215B

OBJECTIVE

To determine the hardness of test panels coated with a lime plaster coating material.

PRODUCT TESTED

The test panels were coated with a pre-mixed lime plaster material identified as:

Shikkui Sora (Shikkui Plaster)

PROCEDURE

The hardness was determined in accordance with the procedures outlined in:

ASTM D 2240 - Standard Test Method for Rubber Property – Durometer Hardness

TEST RESULTS

The ***Shikkui Sora*** pre-mixed lime plaster coating material exhibited the following hardness properties.

Shore A Durometer	95-97
Shore D Durometer	61-62

DL Labs, Inc.

A handwritten signature in black ink, appearing to read 'Mario Lazaro, Jr.'.

Mario Lazaro, Jr.
Assistant Technical Director